

TUBMAN LEAD WATER TEST RESULTS

May 16th, 2016



THE DEPARTMENT OF										• •				
Building Location	1 '	e Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002702	Kitchen	1	In kitchen east wall Left	WT-042916-2719- A	< 1	WT-042916-2719- B	< 1				
2 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002703	Kitchen	1	In kitchen east wall Right	WT-042916-2720- A	< 1	WT-042916-2720- B	< 1				
3 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002704	Cooler	1	In all purpose room east wall	WT-042916-2721- A	< 1	WT-042916-2721- B	< 1				
4 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002705	Other	1	In all purpose room east wall (bottle cooler)	WT-042916-2722- A	< 1	WT-042916-2722- B	< 1				ł
5 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002706	Cooler	3	In hallway adjacent to room 308	WT-042916-2723- A	< 1	WT-042916-2723- B	< 1				
6 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002707	Cooler	3	In hallway adjacent to room 306	WT-042916-2724- A	< 1	WT-042916-2724- B	< 1				
7 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002708	Cooler	3	In hallway adjacent to room 300	WT-042916-2725- A	< 1	WT-042916-2725- B	< 1				
8 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002709	Cooler	3	In hallway adjacent to room 208	WT-042916-2726- A	< 1	WT-042916-2726- B	< 1				ĺ
9 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002710	Cooler	2	In hallway adjacent to room 206	WT-042916-2727- A	< 1	WT-042916-2727- B	< 1				
10 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002711	Cooler	2	In hallway adjacent to 200	WT-042916-2728- A	< 1	WT-042916-2728- B	< 1				
11 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002712	Fountain	1	In health suite	WT-042916-2729- A	< 1	WT-042916-2729- B	< 1				
12 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002713	Health Suite	1	In health suite	WT-042916-2730- A	11.5	WT-042916-2730- B	< 1				ĺ
13 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002714	Break Room	1	In staff lounge room	WT-042916-2731- A	< 1	WT-042916-2731- B	< 1				
14 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002715	Break Room	1	In staff lounge room (spray nozzle)	WT-042916-2732- A	< 1	WT-042916-2732- B	< 1				
15 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002716	Classroom	1	In classroom 128A	WT-042916-2733- A	4.5	WT-042916-2733- B	< 1				
16 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002717	Fountain	1	In classroom 128A	WT-042916-2734- A	1.5	WT-042916-2734- B	< 1				
17 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002718	Other	1	In classroom 128A (ice maker)	WT-042916-2735- A	< 1	WT-042916-2735- B	< 1				
18 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002719	Cooler	1	In hallway adjacent to room 101	WT-042916-2736- A	< 1	WT-042916-2736- B	< 1				
19 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002720	Classroom	1	In classroom 106	WT-042916-2737- A	1.1	WT-042916-2737- B	< 1				
20 TUBMAN ELEMENTARY SO	CHOOL 5/1	0/2016	WS- 002721	Fountain	1	In classroom 106 Right	WT-042916-2738- A	< 1	WT-042916-2738- B	< 1				
21 TUBMAN ELEMENTARY SO		0/2016	WS- 002722	Cooler		In hallway adjacent to room 110	WT-042916-2739- A	60.4	WT-042916-2739- B	7.5	Filter will be installed and then retested			
22 TUBMAN ELEMENTARY SO		0/2016	WS- 002723	Classroom		In classroom 108	WT-042916-2740- A	< 1	WT-042916-2740- B	< 1				
23 TUBMAN ELEMENTARY SO		0/2016	WS- 002724	Fountain	1	In classroom 108	WT-042916-2741- A	< 1	WT-042916-2741- B	< 1				
24 TUBMAN ELEMENTARY SO		0/2016	WS- 002725	Fountain	1	In classroom 111	WT-042916-2742- A	< 1	WT-042916-2742- B	< 1				——
25 TUBMAN ELEMENTARY SO		0/2016	WS- 002726	Fountain	1	In classroom 111	WT-042916-2743- A	< 1	WT-042916-2743- B	< 1				
26 TUBMAN ELEMENTARY SO		0/2016	WS- 002739	Cooler	1	In hallway between room 119 and 117	WT-042916-2756- A	< 1	WT-042916-2756- B	1.5				
27 TUBMAN ELEMENTARY SO		0/2016	WS- 002740	Classroom	1	In classroom across from classroom 122	WT-042916-2757- A	< 1	WT-042916-2757- B	< 1				
28 TUBMAN ELEMENTARY SO		0/2016	WS- 002741	Fountain	1	In classroom 121	WT-042916-2758- A	< 1	WT-042916-2758- B	< 1				
29 TUBMAN ELEMENTARY SO		0/2016	WS- 003988	Classroom		In classroom 110	WT-042916-4005- A	2.7	WT-042916-4005- B	< 1				
30 TUBMAN ELEMENTARY SO		0/2016	WS- 003989	Fountain	1	In classroom 110	WT-042916-4006- A	< 1	WT-042916-4006- B	< 1				-
31 TUBMAN ELEMENTARY SO 32 TUBMAN ELEMENTARY SO		0/2016 0/2016	WS- 003990 WS- 008229	Classroom	1	In classroom 113 In classroom 113	WT-042916-4007- A WT-042916-8246- A	5.5 < 1	WT-042916-4007- B WT-042916-8246- B	< 1				
33 TUBMAN ELEMENTARY SO		,		Fountain										-
		0/2016	WS- 008230	Fountain		In classroom 115	WT-042916-8247- A	< 1	WT-042916-8247- B	< 1				
34 TUBMAN ELEMENTARY SO 35 TUBMAN ELEMENTARY SO		0/2016	WS- 008231	Classroom	1	In classroom 115	WT-042916-8248- A	< 1	WT-042916-8248- B	< 1				
36 TUBMAN ELEMENTARY SO		0/2016 0/2016	WS- 008232 WS- 008233	Classroom	1	In classroom no 114 In classroom 114	WT-042916-8249- A WT-042916-8250- A	1.6	WT-042916-8249- B WT-042916-8250- B	< 1				-
		0/2016		Fountain	1									
37 TUBMAN ELEMENTARY SO 38 TUBMAN ELEMENTARY SO		0/2016	WS- 008234 WS- 008235	Fountain Cooler	1	In hallway adjacent to exit In classroom 120	WT-042916-8251- A WT-042916-8252- A	< 1	WT-042916-8251- B WT-042916-8252- B	< 1				
39 TUBMAN ELEMENTARY SO		0/2016	WS- 008236	Fountain		In classroom no 122 Right	WT-042916-8253- A	< 1	WT-042916-8253- B	< 1	-	-		
40 TUBMAN ELEMENTARY SO		0/2016	WS- 008237	Fountain		In classroom 119	WT-042916-8254- A	< 1	WT-042916-8254- B	< 1	-	-		
41 TUBMAN ELEMENTARY SO 42 TUBMAN ELEMENTARY SO		0/2016	WS- 008238 WS- 008239	Fountain Fountain		In classroom 121 In classroom 122 Mid	WT-042916-8255- A WT-042916-8256- A	1.1	WT-042916-8255- B WT-042916-8256- B	< 1	1			\vdash
43 TUBMAN ELEMENTARY SO		0/2016	WS- 008239 WS- 008240	Cooler		In hallway adjacent 132	WT-042916-8256- A WT-042916-8257- A	< 1	WT-042916-8256- B WT-042916-8257- B	< 1	1			
44 TUBMAN ELEMENTARY SO		0/2016	WS- 008240 WS- 008241	Cooler		In hallway adjacent 132 In hallway adjacent to dinning room	WT-042916-8257- A WT-042916-8258- A	< 1	WT-042916-8257- B WT-042916-8258- B	< 1	1			\vdash
44 TUDIVIAN ELEMENTARY SO	LHUUL 5/1	0/2016	VV3- UU8241	Cooler	1	in nailway aujacent to unning room	M 1-045310-8528- W	< 1	M 1-045310-8529- B	< 1	1	l	l	

Footnotes

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.